

**TABLE FOR ORDINARY MAINTENANCE**

CHECK POINTS	TIME PERIOD				
	1	2	3	6	12
	Months	Months	Months	Months	Months
Check of the electrical connections of the electr. cabinet	X				
Check contacts of remote control switches (if fitted)	X				
Check water circuit for air	X				
Check of electrical connections inside the compressor	X				
Check of the electrical insulation of the compressor					X
Check operation of differential water flow switch	X				
Check operation of the safety components (pressure switch, electric thermal protections)				X	
Check of the dehydrating filter					X
Check of condenser coil cleanliness	X				
Refrigerant charge check	X				
Check of the electrical input power (comp, fans, pumps, etc)			X		